



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/9/09

Code 52.3.10-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition				
Section number and title Table N1102.4.2 Air Barrier and Insulation Inspection		Page 1 of 1				
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member					
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111				
PROPOSED CODE CHANGE (Check One)						
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution						
Add a line to the criteria column in Table N1102.4.2 as follows:						
<p style="text-align: center;">TABLE N1102.4.2 AIR BARRIER AND INSULATION INSPECTION</p> <table border="1"><thead><tr><th>COMPONENT</th><th>CRITERIA</th></tr></thead><tbody><tr><td>Air barrier and thermal barrier</td><td>Exterior thermal envelope insulation for framed walls is installed in substantial contact and continuous alignment with building envelope air barrier Breaks or joints in the air barrier are filled or repaired Air-permeable insulation is not used as a sealing material Air-permeable insulation is inside of an air barrier</td></tr></tbody></table>			COMPONENT	CRITERIA	Air barrier and thermal barrier	Exterior thermal envelope insulation for framed walls is installed in substantial contact and continuous alignment with building envelope air barrier Breaks or joints in the air barrier are filled or repaired Air-permeable insulation is not used as a sealing material Air-permeable insulation is inside of an air barrier
COMPONENT	CRITERIA					
Air barrier and thermal barrier	Exterior thermal envelope insulation for framed walls is installed in substantial contact and continuous alignment with building envelope air barrier Breaks or joints in the air barrier are filled or repaired Air-permeable insulation is not used as a sealing material Air-permeable insulation is inside of an air barrier					
Note: last line in criteria column is added.						
REASON						
This proposal changes the IRC Table N1102.4.2 to bring the IRC into equivalence with the IECC.						
Fiscal impact:						
REVIEW RECOMMENDATION						
Approve						
Disapprove						
Approve as amended						
Further Study						